

TOWN OF HILLSBOROUGH
2017 SEWER SPILL SUMMARY (as of September 27, 2017)

<u>Spill Number</u>	<u>Date</u>	<u>Location</u>	<u>Cause of Spill</u>	<u>Spill Volume (gallons)</u>	<u>Volume Reaching Surface Waters (gal)</u>
1	4/25/2017	Hayes Street outfall, behind Champayne Club	excessive rain	600	600
2	6/20/2017	Hayes Street Outfall, behind Champayne Club	excessive rain	1,800	1,800
3	6/20/2017	Lawndale Pump Station	excessive rain	600	600
4	6/20/2017	Dixie Pump Station	excessive rain	300	300
5	6/20/2017	Cemetery Pump Station	excessive rain	250	250
6	9/16/2017	Corbinton Commons Pump Station	force main rupture in valve vault	500	500
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

TOTAL 4,050 4,050